FICTIONAL SAMPLE - NOT A REAL DOCUMENT

Correction Notice - Framing

Sample Residence - 100 Example Lane

Inspection date: 2026-05-14

Inspection type: Framing

Result: FAILED

Item 1: Missing hold-down at west wall, grid line 1.

Item 2: Header size at W1 does not match approved sheet A-101 Rev 1.

Re-inspection required.