FICTIONAL SAMPLE - NOT A REAL DOCUMENT

RFI 007 - Response

Sample Residence - 100 Example Lane

Question: Confirm header size at W1 after Rev 1 widening.

Answer: Use 2-ply LVL 1-3/4 x 11-7/8 per structural note S-3.

Answered by: Example Engineers (fictional)

Date: 2026-06-02